

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration, pressure device: Pressure transmitters **PCE-28**, **PCE-28P**, differential pressure transmitters **PRE-28**.

Manufacturer: **APLISENS S.A.**,
ul. Morelowa 7,
03-192 Warszawa

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Pressure transmitters **PCE-28**, **PCE-28P**, differential pressure transmitters **PRE-28**
in all versions comply with directive:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A. The following standard was applied: EN 61326-1:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied EN 50581:2012.

Pressure transmitters **PCE-28** in **PED** version comply with directive:

- **PED – 2014/68/EU** dated 15 May 2014

Transmitters in conformity with PED acc. to module H1 are marked with the following certificate marking:

CE-0062-PED-H1-APL 001-17-POL - re. **PCE-28**,

CE-0062-PED-H1D-APL 001-17-POL (design-examination certificate).

Conformity assessment procedure: module H1. NB no. 0062, Bureau Veritas S.A., Newtime - 52 Boulevard du Parc - Ile de la Jatte - 92200 Neuilly sur Seine, France.

The following standards were applied: EN 13445-3:2014; EN ISO 14732:2013; WUDT-UC/2003.

Pressure transmitters **PCE-28**, **PCE-28P**, differential pressure transmitters **PRE-28** in intrinsically safe versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Intrinsically safe versions of transmitters are marked with the following certificate marking:

I M1 Ex ia I Ma

II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb

II 1/2G Ex ia IIC T4 Ga/Gb

(for ALW and ALM type)

II 1D Ex ia IIIC T110°C Da

FTZU 12 ATEX 0193X

Conformity assessment procedure: module B. NB no.1026, Physical Technical Testing Institute,

Pikartska 1337/7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-11:2012, EN 50303:2000.

Notification of quality assurance: module D. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 02.10.2018

Adam Żurawski
General Manager

