

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Feed-through terminal block, nom. voltage: 1000 V, nominal current: 76 A, connection method: Screw connection, number of connections: 2, cross section: 1.5 mm² - 25 mm², AWG: 16 - 4, width: 12.2 mm, height: 54.4 mm, color: gray, mounting type: NS 35/7,5, NS 35/15

Your advantages

- The reducing bridges can be used to connect terminal blocks with different connection technologies, e.g., UT 35 screw terminal block with Push-in technology 2,5 Push-in terminal blocks, to form power blocks
- ☑ Easy and time-saving potential supply and distribution of large currents and cross sections up to 35 mm² with reducing bridges
- The flexible options for reducing bridging in the CLIPLINE complete system can be found in "Accessories for the CLIPLINE complete modular terminal block system"
- Tested for railway applications



COMPLETE BAR

Key Commercial Data

Packing unit	1 pc
Minimum order quantity	50 pc
GTIN	4 017918 977535
GTIN	4017918977535
Weight per Piece (excluding packing)	30.000 g
Custom tariff number	85369010
Country of origin	Turkey

Technical data

General

Number of levels	1
Number of connections	2
Potentials	1
Nominal cross section	16 mm²

10/01/2019 Page 1 / 17



Technical data

General

Color gray Flammability rating according to UL. 94 V0 Area of application Railway industry According to UL. 94 V0 Area of application Rackine building Plant regineering Process industry Rated surge voltage 8 kV Degree of pollution 3 Overvoltage category III Insulating material group 1 Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _k 76 A Nominal current I _k 76 A Nominal voltage U _k 1000 V Open side panel Yes Shock or the hand protection guaranteed Result of surge voltage test setpoint guaranteed Result of power-frequency withstand voltage setpoint 9.8 kV Result of the test for mechanical stability of terminal points (6 x conductor cross section) Test passed Power frequency withstand voltage setpoint 2.2 kV Result of b		
Flammability rating according to UL 94 V0 Area of application Railway industry Machine building Machine building Plant engineering Process industry Rated surge voltage 8 kV Degree of pollution 3 Overvoltage category III Insulating material group I Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal voltage U _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification IEC 60529.2001-02 Back of the hand protection guaranteed Finger protection guaranteed Surge voltage test selpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Bending test troation speed 10 rpm <	Color	
Area of application Railway industry Machine building Plant engineering Process industry Rated surge voltage 8 kV Begree of pollution 3 Overvoltage category IIII Insulating material group III Insulating material group III Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current I _N 76 A Nominal current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification III EC 60529-2001-02 Basck of the hand protection guaranteed Finger protection Surge voltage test setpoint 9.8 kV Result of surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage setpoint 2.2 kV Result of hover-frequency withstand voltage setpoint 10.5 mm² 1.5 mm² Tensile test result Conductor cross section tensile test 1.5 mm² 1.5 mm² 1.5 mm² Tensile test result censile test 1.5 mm² 1.5 mm	-	
Machine building Plant engineering Process industry Rated surge voltage BakV Degree of pollution 3 Overvoltage category III Insulating material group IEVENT STAND STA		
Plant engineering Process industry	Area of application	Railway industry
Rated surge voltage Process industry Degree of poliution 3 Overvoltage category III Insulating material group 1 Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification IEC 60529:2001-02 Bask of the hand protection guaranteed Finger protection guaranteed Surge voltage test setpoint 7 est passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Bending test tordition speed 10 rpm Bending test tordition speed 15 mm² / 0.4 kg Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Testile test result 7 mm² / 4.5 kg Tensile test result		Machine building
Rated surge voltage 8 kV Degree of pollution 3 Overvoltage category III Insulating material group I Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _{ki} 76 A Nominal voltage U _{ki} 1000 V Open side panel Yes Back of the hand protection IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setypoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg <td></td> <td>Plant engineering</td>		Plant engineering
Degree of pollution 3 Overvoltage category III Insulating material group 1 Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test totation speed 10 rpm Bending test tomotuctor cross section/weight 1.5 mm² / 0.4 kg Bending test tomotuctor cross section/weight 1.		Process industry
Overvoltage category III Insulating material group I Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal voltage Un 1000 V Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Trest passed <td>Rated surge voltage</td> <td>8 kV</td>	Rated surge voltage	8 kV
Insulating material group I Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification IEC 60529.2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm²	Degree of pollution	3
Maximum power dissipation for nominal condition 2.43 W Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test truns 135 Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross secti	Overvoltage category	III
Designation Level 1 above 1 below 1 Maximum load current 101 A (with 25 mm² conductor cross section) Nominal current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification EC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Insulating material group	I
Maximum load current I _N 76 A Nominal voltage U _N 1000 V Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Bending test conductor cross section/weight 25 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Maximum power dissipation for nominal condition	2.43 W
Nominal current In 76 A Nominal voltage Un 1000 V Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test rotation speed 15 mm² / 0.4 kg Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Designation	Level 1 above 1 below 1
Nominal voltage U _N Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 8esult of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Bending test rotation speed Bending test turns Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test	Maximum load current	101 A (with 25 mm² conductor cross section)
Open side panel Yes Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm² Conductor cross section tensile test 1.6 mm²	Nominal current I _N	76 A
Shock protection test specification IEC 60529:2001-02 Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Test passed Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed Result of bending test Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg In the second conductor cross section weight 1.5 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Nominal voltage U _N	1000 V
Back of the hand protection guaranteed Finger protection guaranteed Result of surge voltage test Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Test passed Test passed 16 mm² / 2.9 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm² Tiensile test tensile test tensile test 16 mm² Tiensile test tensile test tensile test 16 mm² Tiensile test tensile test tensile test 1.5 mm² Tractive force setpoint 40 N	Open side panel	Yes
Finger protection Result of surge voltage test setpoint Result of power-frequency withstand voltage test Fest passed Power frequency withstand voltage setpoint Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Bending test rotation speed Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg Tensile test result Conductor cross section tensile test 1.5 mm² 4.0 N Conductor cross section tensile test 16 mm² 40 N Conductor cross section tensile test 16 mm² 40 N Conductor cross section tensile test	Shock protection test specification	IEC 60529:2001-02
Result of surge voltage testTest passedSurge voltage test setpoint9.8 kVResult of power-frequency withstand voltage testTest passedPower frequency withstand voltage setpoint2.2 kVResult of the test for mechanical stability of terminal points (5 x conductor connection)Test passedResult of bending testTest passedBending test rotation speed10 rpmBending test turns135Bending test conductor cross section/weight1.5 mm² / 0.4 kg16 mm² / 2.9 kg25 mm² / 4.5 kgTensile test resultTest passedConductor cross section tensile test1.5 mm²Tractive force setpoint40 NConductor cross section tensile test16 mm²	Back of the hand protection	guaranteed
Surge voltage test setpoint 9.8 kV Result of power-frequency withstand voltage test Test passed Power frequency withstand voltage setpoint 2.2 kV Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Test passed Test passed Conductor cross section tensile test 1.5 mm² Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Finger protection	guaranteed
Result of power-frequency withstand voltage test Power frequency withstand voltage setpoint Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Test passed Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg Test passed Conductor cross section tensile test 1.5 mm² Test passed Test passed 40 N Conductor cross section tensile test 16 mm² Test passed	Result of surge voltage test	Test passed
Power frequency withstand voltage setpoint Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Test passed Test passed Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Surge voltage test setpoint	9.8 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Bending test rotation speed Bending test turns Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg 25 mm² / 4.5 kg Tensile test result Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm² Test passed	Result of power-frequency withstand voltage test	Test passed
Result of bending test Result of bending test Bending test rotation speed Bending test turns Bending test conductor cross section/weight 1.5 mm² / 0.4 kg Bending test conductor cross section/weight 1.5 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Power frequency withstand voltage setpoint	2.2 kV
Bending test rotation speed 10 rpm Bending test turns 135 Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg 25 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²		Test passed
Bending test turns Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg 25 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Result of bending test	Test passed
Bending test conductor cross section/weight 1.5 mm² / 0.4 kg 16 mm² / 2.9 kg 25 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Bending test rotation speed	10 rpm
16 mm² / 2.9 kg 25 mm² / 4.5 kg Tensile test result Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Bending test turns	135
25 mm² / 4.5 kg Tensile test result Test passed Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Bending test conductor cross section/weight	1.5 mm² / 0.4 kg
Tensile test result Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²		16 mm² / 2.9 kg
Conductor cross section tensile test 1.5 mm² Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²		25 mm² / 4.5 kg
Tractive force setpoint 40 N Conductor cross section tensile test 16 mm²	Tensile test result	Test passed
Conductor cross section tensile test 16 mm ²	Conductor cross section tensile test	1.5 mm ²
	Tractive force setpoint	40 N
Tractive force setpoint 100 N	Conductor cross section tensile test	16 mm²
	Tractive force setpoint	100 N



Technical data

General

Conductor cross section tensile test	25 mm²
Tractive force setpoint	135 N
Result of tight fit on support	Test passed
Tight fit on carrier	NS 35
Setpoint	5 N
Result of voltage-drop test	Test passed
Requirements, voltage drop	≤ 3.2 mV
Result of temperature-rise test	Test passed
Short circuit stability result	Test passed
Conductor cross section short circuit testing	16 mm²
Short-time current	1.92 kA
Result of thermal test	Test passed
Proof of thermal characteristics (needle flame) effective duration	30 s
Oscillation, broadband noise test result	Test passed
Test specification, oscillation, broadband noise	DIN EN 50155 (VDE 0115-200):2008-03
Test spectrum	Service life test category 1, class B, body mounted
Test frequency	$f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$
ASD level	1.857 (m/s²)²/Hz
Acceleration	0,8 g
Test duration per axis	5 h
Test directions	X-, Y- and Z-axis
Shock test result	Test passed
Test specification, shock test	DIN EN 50155 (VDE 0115-200):2008-03
Shock form	Half-sine
Acceleration	5g
Shock duration	30 ms
Number of shocks per direction	3
Test directions	X-, Y- and Z-axis (pos. and neg.)
Relative insulation material temperature index (Elec., UL 746 B)	130 °C
Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21))	130 °C
Static insulating material application in cold	-60 °C
Behavior in fire for rail vehicles (DIN 5510-2)	Test passed
Flame test method (DIN EN 60695-11-10)	V0
Oxygen index (DIN EN ISO 4589-2)	>32 %
NF F16-101, NF F10-102 Class I	2
NF F16-101, NF F10-102 Class F	2
Surface flammability NFPA 130 (ASTM E 162)	passed



Technical data

General

Specific optical density of smoke NFPA 130 (ASTM E 662)	passed
Smoke gas toxicity NFPA 130 (SMP 800C)	passed
Calorimetric heat release NFPA 130 (ASTM E 1354)	28 MJ/kg
Fire protection for rail vehicles (DIN EN 45545-2) R22	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R23	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R24	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R26	HL 1 - HL 3

Dimensions

Width	12.2 mm
End cover width	2.2 mm
Length	55.5 mm
Height	54.4 mm
Height NS 35/7,5	55 mm
Height NS 35/15	62.5 mm

Connection data

Connection method	Screw connection
Screw thread	M5
Stripping length	14 mm
Tightening torque, min	2.5 Nm
Tightening torque max	3 Nm
Connection in acc. with standard	IEC 60947-7-1
Note	Note: Product releases, connection cross sections and notes on connecting aluminum cables can be found in the download area.
Conductor cross section solid min.	1.5 mm ²
Conductor cross section solid max.	25 mm²
Conductor cross section AWG min.	16
Conductor cross section AWG max.	4
Conductor cross section flexible min.	1.5 mm ²
Conductor cross section flexible max.	25 mm²
Min. AWG conductor cross section, flexible	16
Max. AWG conductor cross section, flexible	4
Conductor cross section flexible, with ferrule without plastic sleeve min.	1 mm²
Conductor cross section flexible, with ferrule without plastic sleeve max.	16 mm²
Conductor cross section flexible, with ferrule with plastic sleeve min.	1 mm²
Conductor cross section flexible, with ferrule with plastic sleeve max.	16 mm²
2 conductors with same cross section, solid min.	1 mm²
2 conductors with same cross section, solid max.	6 mm²

10/01/2019 Page 4 / 17



Technical data

Connection data

2 conductors with same cross section, stranded min.	1 mm²
2 conductors with same cross section, stranded max.	6 mm²
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min.	0.75 mm²
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max.	10 mm²
2 conductors with same cross section, stranded, ferrules without plastic sleeve, min.	1 mm²
2 conductors with same cross section, stranded, ferrules without plastic sleeve, max.	6 mm²
Connection in acc. with standard	IEC/EN 60079-7
Conductor cross section solid min.	1.5 mm²
Conductor cross section solid max.	25 mm ²
Conductor cross section AWG min.	16
Conductor cross section AWG max.	4
Conductor cross section flexible min.	1.5 mm²
Conductor cross section flexible max.	16 mm²
Internal cylindrical gage	A7

Standards and Regulations

Connection in acc. with standard	CSA
	IEC 60947-7-1
Flammability rating according to UL 94	V0
Fire protection for rail vehicles (DIN EN 45545-2) R22	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R23	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R24	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R26	HL 1 - HL 3

Environmental Product Compliance

China RoHS	Environmentally friendly use period: unlimited = EFUP-e
	No hazardous substances above threshold values

Drawings







Classifications

eCl@ss

eCl@ss 4.0	27141100
eCl@ss 4.1	27141100
eCl@ss 5.0	27141100
eCl@ss 5.1	27141100
eCl@ss 6.0	27141100
eCl@ss 7.0	27141120
eCl@ss 8.0	27141120
eCl@ss 9.0	27141120

ETIM

ETIM 2.0	EC000897
ETIM 3.0	EC000897
ETIM 4.0	EC000897
ETIM 5.0	EC000897
ETIM 6.0	EC000897
ETIM 7.0	EC000897

UNSPSC

UNSPSC 6.01	30211811
UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410

Approvals

Approvals

Approvals

DNV GL / CSA / PRS / UL Recognized / cUL Recognized / IECEE CB Scheme / VDE Zeichengenehmigung / EAC / RS / cULus Recognized

Ex Approvals

IECEx / ATEX / EAC Ex

Approval details



Approvals

DNV GL https://approvalfinder.dnvgl.com/ TAE00001S9

CSA (3)	http://www.csagroup.org/services-industries/product-listing/ 13631	
	В	С
Nominal voltage UN	600 V	600 V
Nominal current IN	85 A	85 A
mm²/AWG/kcmil	16-4	16-4

PRS	http://www.prs.pl/	TE/2156/880590/17
-----	--------------------	-------------------

UL Recognized	http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm FILE E 60425	
	В	С
Nominal voltage UN	600 V	600 V
Nominal current IN	85 A	85 A
mm²/AWG/kcmil	16-4	16-4

cUL Recognized	.71	http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm FILE E 60425	
		В	С
Nominal voltage UN		600 V	600 V
Nominal current IN		85 A	85 A
mm²/AWG/kcmil		16-4	16-4

IECEE CB Scheme	CB scheme	http://www.iecee.org/	DE-56827
Nominal voltage UN		1000 V	
Nominal current IN		76 A	



Approvals

mm²/AWG/kcmil	1.5-16

VDE Zeichengenehmigung	₫ŸĒ	http://www2.vde.com/de/Institut/Online-Service/ VDE-gepruefteProdukte/Seiten/Online-Suche.aspx		40020166
Nominal voltage UN			1000 V	
Nominal current IN			76 A	
mm²/AWG/kcmil			1.5-16	

EAC	EAE	RU C- DE.A*30.B.01742
	E11E	

RS		http://www.rs-head.spb.ru/en/index.php	17.00013.272
----	--	--	--------------

cULus Recognized

Accessories

Accessories

DIN rail

DIN rail perforated - NS 35/7,5 PERF 2000MM - 0801733



DIN rail perforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Steel, galvanized, passivated with a thick layer, length: 2000 mm, color: silver



Accessories

DIN rail, unperforated - NS 35/7,5 UNPERF 2000MM - 0801681



DIN rail, unperforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Steel, galvanized, passivated with a thick layer, length: 2000 mm, color: silver

DIN rail perforated - NS 35/7,5 WH PERF 2000MM - 1204119



DIN rail perforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Steel, Galvanized, white passivated, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/7,5 WH UNPERF 2000MM - 1204122



DIN rail, unperforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Steel, Galvanized, white passivated, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/7,5 AL UNPERF 2000MM - 0801704



DIN rail, unperforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Aluminum, uncoated, length: 2000 mm, color: silver

DIN rail perforated - NS 35/ 7,5 ZN PERF 2000MM - 1206421



DIN rail perforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Steel, galvanized, length: 2000 mm, color: silver



Accessories

DIN rail, unperforated - NS 35/7,5 ZN UNPERF 2000MM - 1206434



DIN rail, unperforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Steel, galvanized, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/7,5 CU UNPERF 2000MM - 0801762



DIN rail, unperforated, Standard profile, width: 35 mm, height: 7.5 mm, acc. to EN 60715, material: Copper, uncoated, length: 2000 mm, color: copper-colored

End cap - NS 35/7,5 CAP - 1206560





DIN rail perforated - NS 35/15 PERF 2000MM - 1201730



DIN rail perforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Steel, galvanized, passivated with a thick layer, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/15 UNPERF 2000MM - 1201714



DIN rail, unperforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Steel, galvanized, passivated with a thick layer, length: 2000 mm, color: silver



Accessories

DIN rail perforated - NS 35/15 WH PERF 2000MM - 0806602



DIN rail perforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Steel, Galvanized, white passivated, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/15 WH UNPERF 2000MM - 1204135



DIN rail, unperforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Steel, Galvanized, white passivated, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/15 AL UNPERF 2000MM - 1201756



DIN rail, unperforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Aluminum, uncoated, length: 2000 mm, color: silver

DIN rail perforated - NS 35/15 ZN PERF 2000MM - 1206599



DIN rail perforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Steel, galvanized, length: 2000 mm, color: silver

DIN rail, unperforated - NS 35/15 ZN UNPERF 2000MM - 1206586



DIN rail, unperforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Steel, galvanized, length: 2000 mm, color: silver



Accessories

DIN rail, unperforated - NS 35/15 CU UNPERF 2000MM - 1201895



DIN rail, unperforated, Standard profile, width: 35 mm, height: 15 mm, similar to EN 60715, material: Copper, uncoated, length: 2000 mm, color: copper-colored

End cap - NS 35/15 CAP - 1206573



DIN rail end piece, for DIN rail NS 35/15

DIN rail, unperforated - NS 35/15-2,3 UNPERF 2000MM - 1201798



DIN rail, unperforated, Standard profile 2.3 mm, width: 35 mm, height: 15 mm, acc. to EN 60715, material: Steel, galvanized, passivated with a thick layer, length: 2000 mm, color: silver

End block

End clamp - E/AL-NS 35 - 1201662



End clamp, for end support of UKH 50 to UKH 240, is pushed onto DIN rail NS 35 and fixed with 2 screws, width: 10 mm, color: aluminum

End cover

End cover - D-UT 16 - 3047206



End cover, length: 52.8 mm, width: 2.2 mm, height: 47.3 mm, color: gray



Accessories

Jumper

Plug-in bridge - FBS 2-12 - 3005950



Plug-in bridge, pitch: 12 mm, number of positions: 2, color: red

Labeled terminal marker

Zack marker strip - ZB 12 CUS - 0824942



Zack marker strip, can be ordered: Strip, white, labeled according to customer specifications, mounting type: snap into tall marker groove, for terminal block width: 12.2 mm, lettering field size: 10.5 x 12.15 mm, Number of individual labels: 5

Zack marker strip - ZB 12,LGS:L1-N,PE - 0812146



Zack marker strip, Strip, white, labeled, printed horizontally: L1, L2, L3, N, PE, mounting type: snap into tall marker groove, for terminal block width: 12.2 mm, lettering field size: 10.5 x 12.15 mm, Number of individual labels: 5

Marker for terminal blocks - UC-TM 12 CUS - 0824613



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, mounting type: snap into tall marker groove, for terminal block width: 12 mm, lettering field size: 11.45 x 10.5 mm, Number of individual labels: 40



Accessories

Marker for terminal blocks - UCT-TM 12 CUS - 0829630



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, mounting type: snap into tall marker groove, for terminal block width: 12 mm, lettering field size: 10.8 x 9.6 mm, Number of individual labels: 30

Marker pen

Marker pen - X-PEN 0,35 - 0811228



Marker pen without ink cartridge, for manual labeling of markers, labeling extremely wipe-proof, line thickness 0.35 mm

Partition plate

Partition plate - TPNS-UK - 0706647



Partition plate, length: 80 mm, width: 2 mm, height: 70 mm, color: gray

Pick-off terminal block

Pick-off terminal block - AGK 4-UT 16 - 3047125



Pick-off terminal block, nom. voltage: 1000 V, nominal current: 32 A, connection method: Screw connection, number of connections: 1, cross section: 0.14 mm² - 6 mm², AWG: 26 - 10, width: 8.1 mm, height: 24.7 mm, color: gray, mounting type: on base element

Planning and marking software



Accessories

Software - CLIP-PROJECT ADVANCED - 5146040



Multilingual software for convenient configuration of Phoenix Contact products on standard DIN rails.

Software - CLIP-PROJECT PROFESSIONAL - 5146053



Multilingual software for terminal strip configuration. A marking module enables the professional marking of markers and labels for identifying terminal blocks, conductors and cables, and devices.

Reducing bridge

Reducing bridge - RB UT 16-(2,5/4) - 3047073



Reducing bridge, pitch: 11 mm, length: 31.4 mm, width: 18.1 mm, number of positions: 2, color: red

Reducing bridge - RB UT 16-ST(2,5/4) - 3047099



Reducing bridge, pitch: 11 mm, length: 40.9 mm, width: 18.1 mm, number of positions: 2, color: red

Reducing bridge - RB 16-6 - 3047072



Reducing bridge, pitch: 12.2 mm, number of positions: 2, color: red



Accessories

Screwdriver tools

Screwdriver - SZS 1,0X6,5 VDE - 1205079



Screwdriver, slot-headed, VDE insulated, size: 1.0 x 6.5 x 150 mm, 2-component grip, with non-slip grip

Terminal marking

Zack marker strip - ZB 12:UNPRINTED - 0812120



Zack marker strip, Strip, white, unlabeled, can be labeled with: PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into tall marker groove, for terminal block width: 12.2 mm, lettering field size: 12 x 10.5 mm, Number of individual labels: 5

Marker for terminal blocks - UC-TM 12 - 0819194



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into tall marker groove, for terminal block width: 12 mm, lettering field size: 11.45 x 10.5 mm, Number of individual labels: 40

Marker for terminal blocks - UCT-TM 12 - 0829144



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: TOPMARK NEO, TOPMARK LASER, BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, THERMOMARK PRIME, THERMOMARK CARD 2.0, THERMOMARK CARD, mounting type: snap into tall marker groove, for terminal block width: 12 mm, lettering field size: 10.8 x 9.6 mm, Number of individual labels: 30

Warning label printed



Accessories

Warning label - WS UT 16 - 3047374

Warning sign for UT terminal blocks



Phoenix Contact 2019 © - all rights reserved http://www.phoenixcontact.com